



## Report of Analysis

Mail to: Columbia Borough School District  
200 North 5th Street  
Columbia PA 17512

Lab Number: **284959**  
Date Reported: 01/24/2019

Analyte	Result	Pass/Fail	Maximum Contaminant Level	Analysis		Analyst	Method	Reporting Limit
				Date	Time			
<b>284959-01</b> Sampled: 12/18/2018 11:18 Sampler: DH Source: HS WF 2nd Floor 215 Columbia Borough School District								
Lead	<0.002 mg/L	Pass	0.015 mg/L	01/22/2019		bfm	SM3113b	0.002
This sample meets state and federal standards for safe drinking water, for the parameters reported.								
<b>This sample was not collected by a lab-authorized sampler.</b>								
<b>284959-02</b> Sampled: 12/18/2018 11:15 Sampler: DH Source: HS WF 2nd Floor 202 Columbia Borough School District								
Lead	<0.002 mg/L	Pass	0.015 mg/L	01/22/2019		bfm	SM3113b	0.002
This sample meets state and federal standards for safe drinking water, for the parameters reported.								
<b>This sample was not collected by a lab-authorized sampler.</b>								
<b>284959-03</b> Sampled: 12/18/2018 11:09 Sampler: DH Source: HS Girls Locker WF Columbia Borough School District								
Lead	<0.002 mg/L	Pass	0.015 mg/L	01/22/2019		bfm	SM3113b	0.002
This sample meets state and federal standards for safe drinking water, for the parameters reported.								
<b>This sample was not collected by a lab-authorized sampler.</b>								
<b>284959-04</b> Sampled: 12/18/2018 11:00 Sampler: DH Source: HS WF 1st Floor MS11 Columbia Borough School District								
Lead	<0.002 mg/L	Pass	0.015 mg/L	01/22/2019		bfm	SM3113b	0.002
This sample meets state and federal standards for safe drinking water, for the parameters reported.								
<b>This sample was not collected by a lab-authorized sampler.</b>								
<b>284959-05</b> Sampled: 12/18/2018 11:12 Sampler: DH Source: HS WF 1st Floor Office Columbia Borough School District								
Lead	<0.002 mg/L	Pass	0.015 mg/L	01/22/2019		bfm	SM3113b	0.002
This sample meets state and federal standards for safe drinking water, for the parameters reported.								
<b>This sample was not collected by a lab-authorized sampler.</b>								
<b>284959-06</b> Sampled: 12/18/2018 11:25 Sampler: DH Source: HS WF 1st Floor 103 Columbia Borough School District								
Lead	<0.002 mg/L	Pass	0.015 mg/L	01/22/2019		bfm	SM3113b	0.002
This sample meets state and federal standards for safe drinking water, for the parameters reported.								
<b>This sample was not collected by a lab-authorized sampler.</b>								
<b>284959-07</b> Sampled: 12/18/2018 09:00 Sampler: DH Source: Taylor 2nd Floor WF Columbia Borough School District								
Lead	<0.002 mg/L	Pass	0.015 mg/L	01/22/2019		bfm	SM3113b	0.002
This sample meets state and federal standards for safe drinking water, for the parameters reported.								
<b>This sample was not collected by a lab-authorized sampler.</b>								
<b>284959-08</b> Sampled: 12/18/2018 09:15 Sampler: DH Source: Taylor Nurse Sink Columbia Borough School District								
Lead	<0.002 mg/L	Pass	0.015 mg/L	01/22/2019		bfm	SM3113b	0.002
This sample meets state and federal standards for safe drinking water, for the parameters reported.								
<b>This sample was not collected by a lab-authorized sampler.</b>								
<b>284959-09</b> Sampled: 12/18/2018 09:00 Sampler: DH Source: Taylor Kitchen Sink Columbia Borough School District								
Lead	0.002 mg/L	Pass	0.015 mg/L	01/22/2019		bfm	SM3113b	0.002
This sample meets state and federal standards for safe drinking water, for the parameters reported.								
<b>This sample was not collected by a lab-authorized sampler.</b>								
<b>284959-10</b> Sampled: 12/18/2018 09:00 Sampler: DH Source: Taylor 1st Floor WF Columbia Borough School District								

## Report of Analysis

Mail to: Columbia Borough School District  
 200 North 5th Street  
 Columbia PA 17512

Lab Number: **284959**  
 Date Reported: 01/24/2019

Analyte	Result	Pass/Fail	Maximum Contaminant Level	Analysis		Analyst	Method	Reporting Limit
				Date	Time			
Lead	<0.002 mg/L	Pass	0.015 mg/L	01/22/2019		bfn	SM3113b	0.002

**This sample meets state and federal standards for safe drinking water, for the parameters reported.**

**This sample was not collected by a lab-authorized sampler.**

**284959-11** Sampled: 12/18/2018 09:35 Sampler: DH Source: Park 2nd Floor WF 210 Columbia Borough School District

Lead	<0.002 mg/L	Pass	0.015 mg/L	01/22/2019		bfn	SM3113b	0.002
------	-------------	------	------------	------------	--	-----	---------	-------

**This sample meets state and federal standards for safe drinking water, for the parameters reported.**

**This sample was not collected by a lab-authorized sampler.**

**284959-12** Sampled: 12/18/2018 09:30 Sampler: DH Source: Park 2nd Floor WF 205 Columbia Borough School District

Lead	<0.002 mg/L	Pass	0.015 mg/L	01/22/2019		bfn	SM3113b	0.002
------	-------------	------	------------	------------	--	-----	---------	-------

**This sample meets state and federal standards for safe drinking water, for the parameters reported.**

**This sample was not collected by a lab-authorized sampler.**

**284959-13** Sampled: 12/18/2018 09:50 Sampler: DH Source: Park 2nd Floor WF 205 Columbia Borough School District

Lead	<0.002 mg/L	Pass	0.015 mg/L	01/22/2019		bfn	SM3113b	0.002
------	-------------	------	------------	------------	--	-----	---------	-------

If lead is detected in your drinking water, it probably originated from corrosion of your plumbing system. If your home was built before 1991 and has a metal plumbing system, it is likely that some lead is present. If your water supply is corrosive, then any lead present in the plumbing system may be dissolved into your drinking water. Long-term exposure to lead concentrations in excess of the drinking water standard has been linked to many health effects in adults including cancer, stroke, and high blood pressure. At even greater risk are the fetus and infants up to four years of age, whose rapidly growing bodies absorb lead more quickly and efficiently. Lead can cause premature birth, reduced birth weight, seizures, behavioral disorders, brain damage, and lowered IQ in children.

**This sample meets state and federal standards for safe drinking water, for the parameters reported.**

**This sample was not collected by a lab-authorized sampler.**



The Maximum Contaminant Level (MCL) is the maximum permissible level of a contaminant in water per the SDWA. Some parameters have no established MCL. Pure-Test is certified #38-00338 by the Pennsylvania Department of Environmental Protection, #345 by the Maryland Department of the Environment.



Report Approved By:



Andrew T Heist, Lab Technician